

Consultee Comment for planning application 22/01590/DISC

Application Number	<input type="text" value="22/01590/DISC"/>
Location	<input type="text" value="Os Parcel 4300 North Of Shortlands And South Of High Rock Hook Norton Road Sibford Ferris OX15 5QW"/>
Proposal	<input type="text" value="Discharge of Condition 8 (surface water drainage scheme) of 18/01894/OUT (APP/C3105/W/19/3229631)"/>
Case Officer	<input type="text" value="Daisy Kay-Taylor"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="Drainage/Flood Risk: No further comments. The ground porosity testing results show there is adequate infiltration for the proposed means of surface water drainage using soakaways and an infiltration basin. Calculations have been produced that support the soakaway and infiltration basin designs."/>
Received Date	<input type="text" value="23/07/2022 08:49:08"/>
Attachments	