

# Consultee Comment for planning application 22/02025/REM

<b>Application Number</b>	<input type="text" value="22/02025/REM"/>
<b>Location</b>	<input type="text" value="Bicester Gateway Business Park Wendlebury Road Chesterton"/>
<b>Proposal</b>	<input type="text" value="Reserved Matters to 16/02586/OUT - Access, layout, scale, appearance and landscaping details for Phase 1B for up to 12 No knowledge economy units in Use Class E (former Use Class B) (14,972 sq m gross external area) with associated parking, landscaping, utilities and access"/>
<b>Case Officer</b>	<input type="text" value="Simon Newall"/>
<b>Organisation</b>	<input type="text" value="Building Control (CDC)"/>
<b>Name</b>	<input type="text"/>
<b>Address</b>	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input type="text" value="Boundary conditions for fire and fire brigade access to be in accordance with Approved document B Volume 2"/>
<b>Received Date</b>	<input type="text" value="09/08/2022 14:29:22"/>
<b>Attachments</b>	