

Consultee Comment for planning application 22/02696/DISC

Application Number	<input type="text" value="22/02696/DISC"/>
Location	<input type="text" value="OS Parcels 3309 And 4319 Adjoining And North Of Milton Road Adderbury"/>
Proposal	<input type="text" value="Discharge of Conditions 3 (surface water drainage scheme), 6 (revised plan), 7 (landscaping scheme), 8 (site levels), 9 (surface water drainage scheme), 11 (turning area and parking spaces), 12 (boundary enclosures), 14 (public footpath) and 15 (covered cycle parking facilities) of 18/00220/F"/>
Case Officer	<input type="text" value="Michael Sackey"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="Phase 1
The surface water drainage strategy has been revised and now based on infiltration by means of a porous carrier pipe system beneath the sports pitch surface which has already been installed. The effectiveness of this means has been based on the porosity of the subsoil being <math>1.85 \times 10^{-4}</math> m/s, this reflecting the worst of the tests carried out at a single location near the north-west corner of the pitch. Subject to requiring the applicant to provide reasonable evidence that this porosity is representative of the whole pitch area, I am content to discharge the Condition.

Phase 2
The drainage for Phase 2 is not connected to that of Phase 1. On that basis I am content that the Condition relating to Phase 2 can be discharged."/>
Received Date	<input type="text" value="20/10/2022 08:55:09"/>
Attachments	