Application no: 22/02757/DISC

Location: Hempton Gate Land North Of Hempton Road And West Of, Wimborn Close,

Deddington

Lead Local Flood Authority

Recommendation:

Objection

Detailed comments:

Condition 10 states:

Notwithstanding the information submitted, no development shall commence unless and until a detailed surface water drainage scheme for the site, has been submitted to and approved in writing by the Local Planning Authority. The scheme shall be subsequently be implemented in accordance with the approved details before the development is completed. The scheme shall include:

· A compliance report to demonstrate how the scheme complies with the "Local Standards and Guidance for Surface Water Drainage on Major Development in Oxfordshire":

Discharged according to: DETAILED DRAINAGE DESIGN REPORT FOR PLANNING, REF ES20.020, 18th November 2022

 \cdot Full micro-drainage calculations for all events up to and including the 1 in 100 year plus 40%

climate change;

Discharged according to: SW Network Model - Phase 2.MDX, 09/11/2022

· A Flood Exceedance Conveyance Plan;

Discharged according to drawing 23933 01 230 03

· Comprehensive infiltration testing across the site to BRE DG 365;

The condition states infiltration testing across the site however, only the southern part has been tested. It's understood the basin will be in this part of the site however, if infiltration is feasible in the northern part then the permeable paving can benefit infiltrating into the ground. Please clarify.

· Detailed design drainage layout drawings of the SuDS proposals including cross-section details:

Discharged according to: Private Drive, Construction details, 30.02, Rev P1

· Detailed maintenance management plan in accordance with Section 32 of CIRIA C753 including maintenance schedules for each drainage element, and;

Discharged according to: Technical note, March 2021, : 23933-01-TN-02 REV C

· Details of how water quality will be managed during construction DRG No, ES20.020-0902, cant be found

Reason: To ensure satisfactory drainage of the site and appropriate flood prevention and to comply Policy ESD 7 of the Cherwell Local Plan 2011-2031 Part 1 and with Government guidancecontained within the National Planning Policy Framework.

Officer's Name: Kabier Salam Officer's Title: LLFA Engineer

Date: 07/12/2022