

Consultee Comment for planning application 22/02866/OUT

Application Number	<input type="text" value="22/02866/OUT"/>
Location	<input type="text" value="Land East Of Ploughley Road Ambrosden"/>
Proposal	<input type="text" value="OUTLINE planning application for up to 120 dwellings, vehicular and pedestrian access off Ploughley Road, new pedestrian access to West Hawthorn Road, surface water drainage, foul water drainage, landscaping, public open space, biodiversity and associated infrastructure. Access off Ploughley Road is not reserved for future consideration"/>
Case Officer	<input type="text" value="James Kirkham"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="No comments at this outline stage. It is noted that no infiltration tests have yet been carried out and a positive attenuated surface water discharge is assumed. This should be verified by site BRE 365 tests. Local knowledge suggests that the assumption of very poor soakage will be correct."/>
Received Date	<input type="text" value="24/10/2022 09:41:55"/>
Attachments	