

Lynne Baldwin

From: Neil Whitton
Sent: 01 November 2022 16:28
To: William Anstey
Cc: DC Support
Subject: 22/03063/F - Land East Of, Larsen Road, Upper Heyford, Oxfordshire

Environmental Protection has the following response to this application as presented:

General:

Prior to the commencement of the development, a Construction Environment Management Plan (CEMP), which shall include details of the measures to be taken to ensure construction works do not adversely affect residential properties on, adjacent to or surrounding the site together with details of the consultation and communication to be carried out with local residents shall be submitted to and approved in writing by the Local Planning Authority. Thereafter the development shall be carried out in accordance with approved CEMP

Noise:

Prior to the development commencing a report should be provided and approved in writing by the local planning authority that shows that all habitable rooms within the dwelling and external areas will achieve the noise levels specified in BS8233:2014 (Guidance on sound insulation and noise reduction for buildings) for indoor and external noise levels (if required then the methods for rating the noise in BS4142:2014 should be used, such as for noise from industrial sources). Thereafter, and prior to the first occupation of the dwellings affected by this condition, the dwellings shall be insulated and maintained in accordance with the approved details. If alternative means of ventilation are required then an overheating assessment should be carried out.

Contaminated Land:

Having read the report provided I am satisfied with its contents and agree with its recommendations for further work. Once these have been carried out the verification report should be passed to the LPA for approval, therefore:

A verification report that demonstrates the effectiveness of the remediation carried out must be submitted to and approved in writing by the Local Planning Authority.

Air Quality:

Prior to the commencement of the development hereby permitted a detailed air quality impact assessment to identify the impact of the development on local air quality shall be submitted to and approved in writing by the Local Planning Authority. The assessment should include damage cost calculations where applicable along with a proposal for abatement measures that will be undertaken in addition to those already required from the developer. This shall have regard to the Cherwell District Council Air Quality Action Plan and no development shall take place until the Local Planning Authority has given its written approval that it is satisfied that the impact of the development on air quality has been adequately quantified.

NB: EV Charging provision now falls under Building Regs

Odour:

No comments

Light:

No comments

If you wish to deviate from the suggested conditions then this should be discussed with the officer making these comments to ensure the meaning of the condition remains and that the condition is enforceable and reasonable.

Please note my working pattern below, I will only respond on the days appropriate to the email content Mon – Weds: Environmental Protection, Thurs – Fri: Health Protection and Compliance

Kind Regards

Neil Whitton BSC, MCIEH
Environmental Health Officer
Environmental Health and Licensing
Cherwell District Council
Tel - 01295 221623
Email - Neil.Whitton@cherwell-dc.gov.uk

<http://www.cherwell.gov.uk/>
Find us on Facebook www.facebook.com/cherwelldistrictcouncil

Follow us on Twitter @Cherwellcouncil

This e-mail (including any attachments) may be confidential and may contain legally privileged information. You should not disclose its contents to any other person. If you are not the intended recipient, please notify the sender immediately.

Whilst the Council has taken every reasonable precaution to minimise the risk of computer software viruses, it cannot accept liability for any damage which you may sustain as a result of such viruses. You should carry out your own virus checks before opening the e-mail(and/or any attachments).

Unless expressly stated otherwise, the contents of this e-mail represent only the views of the sender and does not impose any legal obligation upon the Council or commit the Council to any course of action.