PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT

FOCUS TO ADVISE ON REFUSE STRATEGY FOR PLOTS 52-54

PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT

PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT

SEE INSET D

BIN COLLECTION POINT TO BE SHOWN ON MASTERPLAN

PATH REQUIRED FOR OPERATIVE TO COLLECT ROM PLOTS 21-23

SEE INSET C

PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT FROM PLOTS 99-103

FOCUS TO ADVISE ON REFUSE STRATEGY FOR THESE PLOTS. DRAWING 22-192/002 SHOWS THAT IT IS NOT POSSIBLE TO PROVIDE A COLLECTION POINT WITHIN APPROPRIATE DISTANCE OF PLOT 105

SEE INSET B

SEE INSET A

PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT

REFER TO DRAWING 22-192/003 FOR SITE ACCESS DETAILS

BIN COLLECTION POINT TO BE SHOWN ON MASTERPLAN

FOCUS TO ADVISE ON REFUSE STRATEGY FOR PLOT 124. DRAWING 22-192/002 SHOWS PROPOSED BINS STORE LOCATION AND PLOT 124 IS ONLY PLOT THAT CANNOT BE ACCOMMODATED

REPRODUCED FROM ORDNANCE SURVEY Ⓡ BY THE PERMISSION OF THE CONTROLLER OF HER MAJESTY'S STATIONERY OFFICE. © CROWN COPYRIGHT. ALL RIGHTS RESERVED. LICENCE NUMBER 100045322.

INSET A

PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT

INSET B

PATH REQUIRED IN THIS LOCATION TO PROVIDE A ROUTE FOR REFUSE OPERATIVES TO COLLECT

INSET C

REFER TO DRAWING 22-192/003 FOR SITE ACCESS DETAILS

INSET D

NOTES

1. DO NOT SCALE FROM THIS DRAWING. WORK FROM FIGURED DIMENSIONS ONLY.
2. ALL DIMENSIONS SHOWN ON THIS DRAWING ARE IN METRES.
3. COMMENTS BASED ON LAYOUT RECEIVED FROM DAVID WILSON HOMES ON 19/08/22

KEY:-

- SITE BOUNDARY
- 25m OPERATIVE DRAG DISTANCE
- 30m RESIDENTS DRAG DISTANCE



OCC Refuse Vehicle	
Overall Length	11.640m
Overall Width	2.530m
Overall Body Height	3.756m
Min Body Ground Clearance	0.309m
Track Width	2.530m
Lock to lock time	4.00s
Wall to Wall Turning Radius	11.250m

Rev	Amendments	Drn	Chk	App	Date
B	COMMENTS UPDATED TO REVISED LAYOUT	MS	BM	BM	30/08/22
A	MINOR UPDATES TO PROPOSED HIGHWAYS	MS	BM	BM	08/08/22

ODYSSEY

Tuscany House
White Hart Lane
Basingstoke
Hampshire RG21 4AF

Telephone: 01256 331144
Fax: 01256 331134
E: info@odysseyconsult.co.uk
W: www.odysseyconsult.co.uk

Job Title
LAND OFF CAMP ROAD, UPPER HEYFORD

Drawing Title
REFUSE VEHICLE SWEPT PATH ANALYSIS

Client
DAVID WILSON HOMES SOUTHERN

Scale	Date	Designed
1:500 @A1	AUG 22	MS
Drawn	**Checked**	**Approved**
MS	RJH	RJH

Job No	Drawing No	Rev
22-192	22-192/002	B

P:\22-192 - Land off Camp Road, Upper Heyford\Tech\Acad\Drawings\22-192-002 Refuse Vehicle Swept Paths.dwg