

Consultee Comment for planning application 22/03385/DISC

Application Number	<input type="text" value="22/03385/DISC"/>
Location	<input type="text" value="The Beeches Heyford Road Steeple Aston OX25 4SN"/>
Proposal	<input type="text" value="Discharge of Conditions 5 (specification details), 6 (surface water drainage scheme), 7 (Sustainable Construction Statement), 8 (covered cycle storage), 9 (biodiversity method statement), 10 (Construction Traffic Management Plan) and 12 (water efficiency limit) of 21/02147/OUT"/>
Case Officer	<input type="text" value="Michael Sackey"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="No comments in principle. The size(s) of the soakaway(s) will need to be determined at pre-construction stage through soakage tests undertaken at the location(s) where they are proposed as part of Building Control."/>
Received Date	<input type="text" value="16/02/2023 12:33:28"/>
Attachments	