

Consultee Comment for planning application 22/03385/DISC

Application Number	<input type="text" value="22/03385/DISC"/>
Location	<input type="text" value="The Beeches Heyford Road Steeple Aston OX25 4SN"/>
Proposal	<input type="text" value="Discharge of Conditions 5 (specification details), 6 (surface water drainage scheme), 7 (Sustainable Construction Statement), 8 (covered cycle storage), 9 (biodiversity method statement), 10 (Construction Traffic Management Plan) and 12 (water efficiency limit) of 21/02147/OUT"/>
Case Officer	<input type="text" value="Michael Sackey"/>
Organisation	<input type="text" value="CDC - Land Drainage"/>
Name	<input type="text" value="Tony Brummell"/>
Address	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="No further comments. The size(s) of the soakaway(s) will need to be determined at preconstruction stage through soakage tests undertaken at the location(s) where they are proposed as part of Building Control."/>
Received Date	<input type="text" value="08/03/2023 09:54:24"/>
Attachments	