

Rachel Tibbetts

From: Neil Whitton
Sent: 10 January 2023 14:46
To: Hansah Iqbal
Cc: DC Support
Subject: 22/03866/DISC - Bicester Heritage, Buckingham Road, Bicester, Oxfordshire

Environmental Protection has the following response to this application as presented:

Having read the noise report provided I am happy that the condition can be discharged provided that both the silencer and acoustic fence recommended as mitigation are installed prior to the first use of the premises.

Please note my working pattern below, I will only respond on the days appropriate to the email content Mon – Weds: Environmental Protection, Thurs – Fri: Health Protection and Compliance

Kind Regards

Neil Whitton BSC, MCIEH
Environmental Health Officer
Environmental Health and Licensing
Cherwell District Council
Tel - 01295 221623
Email - Neil.Whitton@cherwell-dc.gov.uk

<http://www.cherwell.gov.uk/>
Find us on Facebook www.facebook.com/cherwelldistrictcouncil

Follow us on Twitter @Cherwellcouncil