

Consultee Comment for planning application 23/00173/OUT

Application Number	<input type="text" value="23/00173/OUT"/>
Location	<input type="text" value="Land South Of Green Lane Chesterton"/>
Proposal	<input type="text" value="Outline planning application for up to 147 homes, public open space, flexible recreational playing field area and sports pitches with associated car parking, alongside landscaping, ecological enhancements, SuDs, green/blue and hard infrastructure, with vehicular and pedestrian/cycle accesses, and all associated works (all matters reserved except for means of access)"/>
Case Officer	<input type="text" value="Andrew Thompson"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text" value="Building Control"/>
Address	<input type="text" value="Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="A Building Regulations application will be required. Please note that the proposed dwellings will need to meet the additional requirements of Part M: 'Access to and use of buildings', Part R: 'Infrastructure for electronic communications' and Part S: 'Infrastructure for charging electric vehicles'."/>
Received Date	<input type="text" value="15/02/2023 16:49:05"/>
Attachments	