

Consultee Comment for planning application 23/00438/F

Application Number	23/00438/F
Location	Mole End Main Street Wendlebury Bicester OX25 2PS
Proposal	Demolition of outbuilding; two storey extension to side and rear of existing dwelling - Re-submission of 22/01049/F
Case Officer	Hansah Iqbal
Organisation	CDC - Land Drainage
Name	Tony Brummell
Address	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	No objections in principle. There is shown to be a high risk of surface water flooding at the site which means that overland flows cannot readily drain. The applicant should ensure that this is taken account of in the site drainage design.
Received Date	15/03/2023 13:55:58
Attachments	