

Application no: 23/01586/REM

Location: Proposed Himley Village North West Bicester, Middleton Stoney Road, Bicester

Lead Local Flood Authority

Recommendation:

Holding objection

Key issues:

- Revised hydraulic calculations are required to accompany the updated drainage layout.

Detailed comments:

Phase 2A Drainage Strategy Sheet 1 of 2 -27141-HYD-PH2A-XX-DR-C-2310-P01 has now been updated to revision P03. The hydraulic calculations should be updated to account for the changes in the drainage layout, ensuring that the drainage system remains suitable for the proposed development.

Officer's Name: Thomas Callaway

Officer's Title: Technical Lead – SUDs drainage engineer

Date: 31/7/24