

# Consultee Comment for planning application 23/01711/REM

<b>Application Number</b>	23/01711/REM
<b>Location</b>	Land North Of Bicester Avenue Garden Centre Oxford Road Bicester
<b>Proposal</b>	Reserved matters approval for 17/02534/OUT - Proposed construction of a sub-station with all associated works
<b>Case Officer</b>	Tom Webster
<b>Organisation</b>	CDC - Land Drainage
<b>Name</b>	Tony Brummell
<b>Address</b>	Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
<b>Type of Comment</b>	Comment
<b>Type</b>	
<b>Comments</b>	No comments on surface water drainage strategy and details. However, more details required of foul drainage. A septic tank will not be acceptable.
<b>Received Date</b>	21/07/2023 17:28:23
<b>Attachments</b>	