

Consultee Comment for planning application 23/01969/DISC

| | |
|---------------------------|---|
| Application Number | 23/01969/DISC |
| Location | Oxford Technology Park Technology Drive Kidlington OX5 1GN |
| Proposal | Discharge of Condition 6 (SuDS Compliance Report) of 22/02214/F |
| Case Officer | Hansah Iqbal |
| Organisation | CDC - Land Drainage |
| Name | Tony Brummell |
| Address | Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA |
| Type of Comment | Comment |
| Type | |
| Comments | The applicant has undertaken ground porosity tests and based the surface water drainage on the findings of those. On the basis that the findings are representative of the entire site and the flood exceedance routes are as shown on the drawings within the SuDS Compliance Report I have no objections. The Planning Condition can be discharged. |
| Received Date | 04/08/2023 09:44:15 |
| Attachments | |