

**Chancel Cottage Fir Lane Steeple Aston OX25
4SF**

23/02132/DISC

Case Officer: Shona King

Recommendation: Approve

Applicant: Mr Justin Grainger

Proposal: Discharge of Condition 5 (material samples) of 21/03592/F

Expiry Date: 28 September 2023

Extension of Time:

The application seeks the discharge of Condition 5 (material samples) of 21/03592/F.

The condition requires the approval of a sample panel of the stonework for the garden studio. The sample panel was viewed on site on 13th September 2023.

RECOMMENDATION

That Planning Condition 5 (material samples) of 21/03592/F be discharged based upon the following:

Condition 5

Stone sample panel viewed on site on 13th September 2023. Stone from Cotswold Natural Stone companies Oxleaze Quarry or Grange Hill Quarry. The lime mortar mix - 3:1 NHL 3.5

Case Officer: Shona King

DATE: 26 September 2023

Checked By: Nathanael Stock

DATE: 27.09.2023
