

Consultee Comment for planning application 23/02299/DISC

Application Number	23/02299/DISC
Location	Land North Of Bicester Avenue Garden Centre Oxford Road Bicester
Proposal	Discharge of Conditions 9 (Surface Water Drainage Strategy), 13 (Phasing Plan), 15 (Contaminated Land ? Desk Study), 16 (Contaminated Land ? Intrusive Investigation Report) and 17 (Contaminated Land ? Remediation Scheme) of 17/02534/OUT
Case Officer	Tom Webster
Organisation	Environmental Health (CDC)
Name	Environmental Health (CDC)
Address	Environmental Health Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
Type of Comment	Comment
Type	
Comments	<p>Environmental Protection have the following comments to make on this discharge application:</p> <p>Conditions 15 and 16 can be discharged however I am unable to recommend the discharge of condition 17 (Remediation Scheme) as one hasn't been provided despite the need for remediation being identified in the phase 2 report regarding asbestos and the need for a clean cover.</p> <p>Neil Whitton EHO</p>
Received Date	18/09/2023 10:22:12
Attachments	