

# Consultee Comment for planning application 23/02338/OUT

<b>Application Number</b>	23/02338/OUT
<b>Location</b>	Land West Of Oxford Close And North Of Corner Farm Station Road Kirtlington
<b>Proposal</b>	Erection of 15 detached and semi-detached single and two-storey dwellings (including affordable housing) together with access, parking, amenity space and landscaping - re-submission of 22/03049/OUT
<b>Case Officer</b>	Jeanette Davey
<b>Organisation</b>	Building Control (CDC)
<b>Name</b>	Building Control
<b>Address</b>	Building Control Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA
<b>Type of Comment</b>	Comment
<b>Type</b>	
<b>Comments</b>	The proposed development will require a Building Regulations application will be required. Part S of the Building Regulations requires E.V charging for each dwelling.
<b>Received Date</b>	10/10/2023 10:35:45
<b>Attachments</b>	