

# Consultee Comment for planning application 23/02354/DISC

<b>Application Number</b>	<input type="text" value="23/02354/DISC"/>
<b>Location</b>	<input type="text" value="Land North Of Bicester Avenue Garden Centre Oxford Road Bicester"/>
<b>Proposal</b>	<input type="text" value="Discharge of Conditions 6 (ground levels), 10 (surface water drainage scheme), 12 (biodiversity statement), 14 (foul drainage scheme), 20 (means of access) and 24 (Site Walkover Survey) for Phase 4 (sub-station) of 17/02534/OUT"/>
<b>Case Officer</b>	<input type="text" value="Tom Webster"/>
<b>Organisation</b>	<input type="text" value="Land Drainage (CDC)"/>
<b>Name</b>	<input type="text" value="Tony Brummell"/>
<b>Address</b>	<input type="text" value="Cherwell District Council Bodicote House White Post Road Bodicote Banbury OX15 4AA"/>
<b>Type of Comment</b>	<input type="text" value="Comment"/>
<b>Type</b>	<input type="text"/>
<b>Comments</b>	<input accommodate="" be="" effluent="" generated="" of="" on="" pumped="" relatively="" saniflo"="" should="" site."="" small="" system="" the="" this="" to="" type="text" untreated="" used="" value="Objection. The foul water drainage disposal strategy shown on drawing 082005-CUR-00-XX-DR-C-92003 - P02 indicates this to be to a cesspit. This is not acceptable due to the close proximity of a watercourse. An alternative means of disposal such as a " volumes="" which="" will=""/>
<b>Received Date</b>	<input type="text" value="12/11/2023 09:09:13"/>
<b>Attachments</b>	