

Chris Wentworth

From: Tim Screen
Sent: 12 October 2023 17:27
To: Chris Wentworth
Subject: 23/02713/DISC - OS Parcel 6372 South East Of Milestone Farm, Broughton Road, Banbury

Hi Chris

The PROW General Arrangement is concerning because of the excavations within the root protection area of existing retained trees and hedgerow putting them at risk, reducing their amenity, and their screening potential for visual receptors. All works must be reconsidered in accordance with **BS5837: 2012 Trees in relation to design, demolition and construction – Recommendations**. A qualified arboriculturist must assess the proposals and provide the most appropriate solution to this matter, whether a raised surface solution or mown or mulched path.

Best regards

Tim

Tim Screen CMLI
Landscape Architect
Environmental Services
Environment & Place
Cherwell District Council
01295 221862

mailto:tim.screen@cherwell-dc.gov.uk

www.cherwell-dc.gov.uk

www.facebook.com/cherwelldistrictcouncil

Follow us on Twitter: @Cherwellcouncil



Cherwell
DISTRICT COUNCIL
NORTH OXFORDSHIRE