

Application no: 23/02713/DISC

Location: OS Parcel 6372 South East Of Milestone Farm, Broughton Road, Banbury

Lead Local Flood Authority

Recommendation:

No Objection to Discharge of condition 10 SW Scheme

Document reviewed: Balmoral Avenue, Banbury (Phase 2) SUDS Management Strategy September 2023 REPORT REF: 27526-CIVL-0202

Detailed comments:

The inlet and outlet pipes are in close proximity. The forebay area should be increased in proportion to the size of the proposed pond.

Officer's Name: Shada Hasan

Officer's Title: LLFA Engineer

Date: 20th October 2023