

Lynne Baldwin

From: BCTAdmin@thameswater.co.uk
Sent: 27 June 2024 13:00
To: Planning
Subject: 3rd Party Planning Application - 24/01605/DISC

CAUTION: This email originated from outside of the Council. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Cherwell District Council Our DTS Ref: 44012
Planning & Development Services Your Ref: 24/01605/DISC
Bodicote House
Bodicote, Banbury
Oxon
OX15 4AA

27 June 2024

Dear Sir/Madam

Re: PROPOSED HIMLEY VILLAGE NORTH WEST BICESTER, MIDDLETON STONEY ROAD (PHASE 2A),
BICESTER, OXFORDSHIRE, OX26

Waste Comments

Thank you for consulting Thames Water for the discharge of matters relating to FOUL WATER networks. Thames Water confirms the foul water condition referenced, can be discharged based on the information submitted. .

Water Comments

Supplementary Comments

Thank you for consulting Thames Water for the discharge of matters relating to FOUL WATER for condition 34 (Foul Drainage Strategy) of 14/02121/OUT for Phases 1A & 1B. Thames Water confirms the foul water condition referenced can be discharged based on the information submitted.

Drainage strategy plans indicate that the Foul flows gravitate to an adoptable pumping station prior to pumping at 11.7 l/s via rising main to a FWMH situated off Howes Lane referenced as SP5623 7254. Thames Water do not have any network capacity concerns with this proposal, and would encourage the developer to engage with us should their proposed drainage requirements change in the future.

Yours faithfully
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ
Tel:020 3577 9998
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to

devcon.team@thameswater.co.uk

Visit us online www.thameswater.co.uk, follow us on twitter www.twitter.com/thameswater or find us on www.facebook.com/thameswater. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.