

Consultee Comment for planning application 25/02812/F

| | |
|---------------------------|--|
| Application Number | <input type="text" value="25/02812/F"/> |
| Location | <input type="text" value="The Small House Small House Sibford Ferris Oxfordshire OX15 5RG"/> |
| Proposal | <input type="text" value="Demolition of existing single storey extensions and garage and erection of new single and two storey extensions"/> |
| Case Officer | <input type="text" value="Iwona Gogut"/> |
| Organisation | <input type="text" value="Building Control (CDC)"/> |
| Name | <input type="text"/> |
| Address | <input type="text" value="Building Control Cherwell District Council 39 Castle Quay Banbury OX16 5FD"/> |
| Type of Comment | <input type="text" value="Comment"/> |
| Type | <input type="text"/> |
| Comments | <input type="text" value="The proposal is subject to the Building Regulations, and will require an application to be submitted to a Building Control body for approval. Please note that the flue for the wood-burning stove will need to be extended higher by about a metre or so (than shown in the elevation drawing), to comply."/> |
| Received Date | <input type="text" value="12/11/2025 12:56:38"/> |
| Attachments | |