

Consultee Comment for planning application 25/02824/F

Application Number	<input type="text" value="25/02824/F"/>
Location	<input type="text" value="2 Shepherds Close Burdrop Oxfordshire OX15 5RN"/>
Proposal	<input type="text" value="The erection of one new two storey self-build dwelling alongside No 2 Shepherds Close, with all associated works"/>
Case Officer	<input type="text" value="Michael Sackey"/>
Organisation	<input type="text" value="Building Control (CDC)"/>
Name	<input type="text"/>
Address	<input type="text" value="Building Control Cherwell District Council 39 Castle Quay Banbury OX16 5FD"/>
Type of Comment	<input type="text" value="Comment"/>
Type	<input type="text"/>
Comments	<input type="text" value="The proposal is subject to the Building Regulations, and will require an application to be submitted to a Building Control body for approval.
Please note that the new habitable rooms on first floor will need emergency egress windows."/>
Received Date	<input type="text" value="12/11/2025 15:10:55"/>
Attachments	