

From: [Planning](#)
To: [DC Support](#)
Subject: FW: 3rd Party Planning Application - 26/00086/F
Date: 13 February 2026 10:58:43

From: devcon.team@thameswater.co.uk <devcon.team@thameswater.co.uk>
Sent: 13 February 2026 10:54
To: Planning <Planning@Cherwell-DC.gov.uk>
Subject: 3rd Party Planning Application - 26/00086/F

CAUTION: This email originated from outside of the Council. Do not click links or open attachments unless you recognise the sender and know the content is safe.

Cherwell District Council, Planning & Development Services, , Bodicote, Banbury, Oxon, OX15 4AA

13 February 2026

Our DTS Ref: 80476
Your Ref: 26/00086/F

Dear Sir/Madam,

Re: BUILDINGS, DOVECOTE FARM, HEYFORD ROAD, SOMERTON, SOMERTON, OX25

Waste Comments:

Waste Comments: Following initial investigations, Thames Water has identified an inability of the existing SEWAGE TREATMENT WORKS infrastructure to accommodate the needs of this development proposal. As such Thames Water request the following condition be added to any planning permission. "No development shall be occupied until confirmation has been provided that either:- all sewage works upgrades required to accommodate the additional flows from the development have been completed; or - a development and infrastructure phasing plan has been agreed with the Local Authority in consultation with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason – Sewage Treatment Upgrades are likely to be required to accommodate the proposed development. Any upgrade works identified will be necessary in order to avoid sewage flooding and/or potential pollution incidents. Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed

illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing trade.effluent@thameswater.co.uk . Application forms should be completed on line via www.thameswater.co.uk. Please refer to the Wholesale; Business customers; Groundwater discharges section.

Thames Water would advise that with regard to the FOUL WATER network capacity, we would not have any objection to the above planning application, based on the information provided.

The application indicates that SURFACE WATER will NOT be discharged to the public network and as such Thames Water has no objection, however approval should be sought from the Lead Local Flood Authority. Should the applicant subsequently seek a connection to discharge surface water into the public network in the future then we would consider this to be a material change to the proposal, which would require an amendment to the application at which point we would need to review our position.

Water Comments:

Water Comments: The proposed development is located within 5m of a strategic water main. Thames Water do NOT permit the building over or construction within 5m, of strategic water mains. Thames Water request that the following condition be added to any planning permission. No construction shall take place within 5m of the water main. Information detailing how the developer intends to divert the asset / align the development, so as to prevent the potential for damage to subsurface potable water infrastructure, must be submitted to and approved in writing by the local planning authority in consultation with Thames Water. Any construction must be undertaken in accordance with the terms of the approved information. Unrestricted access must be available at all times for the maintenance and repair of the asset during and after the construction works. Reason: The proposed works will be in close proximity to underground strategic water main, utility infrastructure. The works has the potential to impact on local underground water utility infrastructure. Please read our guide 'working near our assets' to ensure your workings will be in line with the necessary processes you need to follow if you're considering working above or near our pipes or other structures.
<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes> Should you require further information please contact Thames Water. Email: developer.services@thameswater.co.uk.

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.
<https://www.thameswater.co.uk/developers/larger-scale-developments/planning-your-development/working-near-our-pipes>

On the basis of information provided, Thames Water would advise that with regard to

water network infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Supplementary Comments:

Yours faithfully,
Development Planning Department

Development Planning,
Thames Water,
Maple Lodge STW,
Denham Way,
Rickmansworth,
WD3 9SQ,
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk