

**Summary Sheet - POL Tanks**

POL Ref	Tank Ref (Facility No.)	Tank Volume (m <sup>3</sup> )	Tank sample Lab Report No.	TPH concentration (µg/L)	Headspace TVOC (ppm v/v)	Approximate volume dewatered (m <sup>3</sup> )	Cleaned and De-gassed Certificate No.	PFA Filled	Comments
POL 1	1	168	13991	120	0.0	168	319	Yes	Cork gasket
POL 2	2A	55	139564	1300	0.0	48.00	2432	Yes	Cork gasket
	2B	55	139564	360	0.0	56.00	2433	Yes	Cork gasket
	2C	55	139564	580	0.0	56.00	2434	Yes	Cork gasket
	2D	55	139564	640	0.0	51.00	2435	Yes	Cork gasket
	2E	55	139564	6100	4.7	52.00	2439	Yes	Cork gasket
	2F	55	139611	330	0.0	52.80	2440	Yes	Cork gasket
	2G	55	13991	110000	5.6	52.40	316	Yes	Cork gasket
	2H	55	13991	85000	1.2	52.10	317	Yes	Cork gasket
	2J	55	13991	1100	0.9	54.90	318	Yes	Cork gasket
	2K	55	13991	120000	3.5	53.30	315	Yes	Cork gasket
	2L	55	13991	260	3.9	49.20	313	Yes	Cork gasket
2M	55	13991	3000	7.4	55.90	314	Yes	Cork gasket	
POL 3	3A	189	119684	40000	86.0	189.50	2447	Yes	Cork gasket
	3B	189	119684	6800	29.7	121.20	2448	Yes	Cork gasket
POL 5	5A	189	59583	<10	0.0	189.00	1788	Yes	Cork gasket
	5B	189	59583	<10	0.0	189.00	1787	Yes	Cork gasket
POL 6	6	189	59583	<10	0.5	189.00	1789	Yes	Cork gasket
POL 7	7	189	139562	<10	0.5	188.00	1770	Yes	Cork gasket
POL 8	8	189	139562	<10	0.2	188.00	1774	Yes	Cork gasket
POL 9	9A	189	119585	2000	0.0	188.10	2445	Yes	Cork gasket
	9B	189	119585	<10	0.0	188.00	2446	Yes	Cork gasket
POL 10	10A	189	119585	<10	0.0	189.00	1767	Yes	Cork gasket
	10B	189	119585	<10	0.0	189.00	1768	Yes	Cork gasket
POL 11	11	189	139389	<10	0.2	189.00	1769	Yes	AIB Gasket
POL 12	12A	15.1	139389	83	10.2	8.00	2441	Yes	AIB Gasket
	12B	15.1	139389	3100	27.6	14.00	2442	Yes	AIB Gasket
POL 13	13	189	139564	<10	0.4	189.00	1792	Yes	AIB Gasket
POL14	14A	189	139389	170000	3.0	182.40	2437	Yes	AIB Gasket
	14B	189	139389	730	1.6	194.00	2436	Yes	AIB Gasket
POL 15	15A (AST)	0	N/A	0	0.0	0.00	1790	No	POL15A, above ground storage tank to be retained. No filling required. Cork gasket.
	15B	188	139564	<10	0.0	180.00	2443	Yes	Cork gasket
	15C	188	139564	<10	0.0	180.00	2444	Yes	Cork gasket
POL 16	16	189	119556	120	0.0	185.00	2431	Yes	Cork gasket
POL 17	17A	55	119556	230	11.7	40.60	2420	Yes	AIB Gasket
	17B	55	119556	<10	35.3	38.50	2421	Yes	AIB Gasket
	17C	55	119556	10	26.9	37.80	2422	Yes	AIB Gasket
	17D	55	119556	<10	22.0	26.30	2424	Yes	AIB Gasket
	17E	55	N/A	No sample, tank dry	2.9	0.00	2425	Yes	AIB Gasket
	17F	55	119556	22	42.7	33.50	2423	Yes	AIB Gasket
	17G	55	119585	<10	0.0	55.00	2426	Yes	AIB Gasket
	17H	55	119585	<10	0.6	50.30	2427	Yes	AIB Gasket
	17J	55	119584	<10	0.3	51.00	2428	Yes	AIB Gasket
	17K	55	119584	700	1.0	54.00	2429	Yes	AIB Gasket
17L	55	119584	<10	0.2	55.00	2430	Yes	AIB Gasket	

POL Ref	Tank Ref (Facility No.)	Tank Volume (m <sup>3</sup> )	Tank sample Lab Report No.	TPH concentration	Headspace TVOC (ppm)	Approximate volume	Cleaned and De-gassed	PFA Filled	Comments
POL 17	17M	55	119584	100	0.0	52.00	2438	Yes	AIB Gasket
POL 20	20A	56	139562	840	0.0	56.00	1778	Yes	Cork gasket
	20B	56	139562	32000	0.0	56.00	1779	Yes	Cork gasket
	20C	56	139562	44000	50.0	56.00	1780	Yes	Cork gasket
	20D	56	139611	3200	0.0	56.00	1781	Yes	Cork gasket
	20E	56	139611	37000	16.5	56.00	1782	Yes	Cork gasket
	20F	56	139611	860	0.0	56.00	1783	Yes	Cork gasket
	20G	56	139611	5000	0.0	56.00	1771	Yes	Cork gasket
	20H	56	139611	3200	0.0	56.00	1772	Yes	Cork gasket
	20J	56	119619	4700	0.0	56.00	1773	Yes	Cork gasket
	20K	56	119619	1400	0.0	56.00	1776	Yes	Cork gasket
	20L	56	119619	1700	466.0	56.00	1775	Yes	Cork gasket
20M	56	119619	10000	3444.0	56.00	1777	Yes	Cork gasket	
POL 21	21A	400	119684	2700	116.0	40.00	1795	No	Cork gasket
	21B	980	119684	23000	130.0	98.00	1796	No	Cork gasket
	21C	1,640	119684	34000	160.0	164.00	1797	No	Cork gasket
POL 22	22	343	139611	22000	34.0	343.00	1799	No	AIB Gasket
POL 23	23A	746	119619	<10	25.0	746.00	326	Yes	AIB Gasket
	23B	387	119619	15000	13.0	387.00	1784	No	AIB Gasket
	23C	4.5	N/A	N/A	N/A	4.50	2449	Yes	Cork gasket
	23D	4.5	N/A	N/A	N/A	4.50	2450	Yes	Cork gasket
POL 24	24	550	59679	230000	0.0	550.00	2303	No	AIB Gasket
	24A	4.5	N/A	N/A	N/A	4.50	331	Yes	Cork gasket
POL 25	25A	3,780	13991	150	0.0	427.30	1785	No	AIB Gasket
	25B	3,860	13991	160	0.0	386.00	1791	Yes	AIB Gasket
	25C	4.5	N/A	N/A	N/A	4.50	347	Yes	AIB Gasket

Summary	No Tanks	Total Tank Volume (m <sup>3</sup> )
	71	18,294

Volume dewatered (m <sup>3</sup> )	No tanks cleaned and De gassed
8456	71