


Woods Hardwick		Page 1
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions		Network 2014.1.1

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes MANHOLESFA5





FEH Rainfall Model

Return Period (years)	2
Site Location GB 450500 225250 SP 50500 25250	
C (1km)	-0.023
D1 (1km)	0.328
D2 (1km)	0.309
D3 (1km)	0.264
E (1km)	0.292
F (1km)	2.461
Maximum Rainfall (mm/hr)	0
Maximum Time of Concentration (mins)	30
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	0.750
Add Flow / Climate Change (%)	0
Minimum Backdrop Height (m)	0.000
Maximum Backdrop Height (m)	0.000
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Network Design Table for Storm


















- Indicates pipe length does not match coordinates

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
1.000	23.076	0.160	144.2	0.057	6.00	0.0	0.600	o	225	
1.001	33.695	0.150	224.6	0.045	0.00	0.0	0.600	o	300	
1.002	30.293	0.190	159.4	0.100	0.00	0.0	0.600	o	300	
1.003	15.572	0.100	155.7	0.078	0.00	0.0	0.600	o	300	

Network Results Table


PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.000	0.00	6.35	124.500	0.057	0.0	0.0	0.0	1.09	43.2	0.0
1.001	0.00	6.89	124.265	0.102	0.0	0.0	0.0	1.04	73.9	0.0
1.002	0.00	7.30	124.115	0.202	0.0	0.0	0.0	1.24	87.8	0.0
1.003	0.00	7.50	123.925	0.280	0.0	0.0	0.0	1.26	88.9	0.0

Network Design Table for Storm















PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
2.000	18.369	0.275	66.8	0.060	6.00	0.0	0.600	o	300	
1.004	24.458	0.095	257.5	0.031	0.00	0.0	0.600	o	450	
1.005	24.204	0.080	302.6	0.138	0.00	0.0	0.600	o	450	
1.006	54.633	0.175	312.2	0.129	0.00	0.0	0.600	o	450	
1.007	22.722	0.104	218.5	0.010	0.00	0.0	0.600	oo	41	
1.008	65.735#	0.136	483.3	0.071	0.00	0.0	0.600	o	525	
1.009	8.406	0.020	420.3	0.000	0.00	0.0	0.600	o	525	
3.000	43.030	0.230	187.1	0.090	6.00	0.0	0.600	o	300	
3.001	4.430	0.030	147.7	0.000	0.00	0.0	0.600	o	300	
3.002	42.281	0.175	241.6	0.067	0.00	0.0	0.600	o	300	
1.010	16.811	0.038	442.4	0.000	0.00	0.0	0.600	o	525	
1.011	24.443	0.062	394.2	0.000	0.00	0.0	0.600	3 \=/	525	
1.012	3.190	0.010	319.0	0.000	0.00	0.0	0.600	o	525	
1.013	9.350	0.019	492.1	0.000	0.00	0.0	0.600	o	525	
4.000	48.968	0.170	288.0	0.096	6.00	0.0	0.600	o	375	
4.001	29.802	0.100	298.0	0.060	0.00	0.0	0.600	o	375	
4.002	13.142	0.054	243.4	0.022	0.00	0.0	0.600	o	375	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
2.000	0.00	6.16	123.950	0.060	0.0	0.0	0.0	1.93	136.2	0.0
1.004	0.00	7.83	123.675	0.371	0.0	0.0	0.0	1.26	200.8	0.0
1.005	0.00	8.17	123.580	0.509	0.0	0.0	0.0	1.16	185.1	0.0
1.006	0.00	8.97	123.500	0.638	0.0	0.0	0.0	1.15	182.1	0.0
1.007	0.00	9.33	123.250	0.648	0.0	0.0	0.0	1.06	149.2	0.0
1.008	0.00	10.41	123.146	0.719	0.0	0.0	0.0	1.01	219.1	0.0
1.009	0.00	10.54	123.010	0.719	0.0	0.0	0.0	1.09	235.1	0.0
3.000	0.00	6.63	123.650	0.090	0.0	0.0	0.0	1.15	81.0	0.0
3.001	0.00	6.68	123.420	0.090	0.0	0.0	0.0	1.29	91.3	0.0
3.002	0.00	7.38	123.390	0.157	0.0	0.0	0.0	1.01	71.2	0.0
1.010	0.00	10.80	122.990	0.876	0.0	0.0	0.0	1.06	229.1	0.0
1.011	0.00	11.24	122.952	0.876	0.0	0.0	0.0	0.94	137.5	0.0
1.012	0.00	11.28	122.890	0.876	0.0	0.0	0.0	1.25	270.3	0.0
1.013	0.00	11.43	122.880	0.876	0.0	0.0	0.0	1.00	217.1	0.0
4.000	0.00	6.77	123.100	0.096	0.0	0.0	0.0	1.06	117.3	0.0
4.001	0.00	7.24	122.930	0.156	0.0	0.0	0.0	1.04	115.3	0.0
4.002	0.00	7.43	122.830	0.178	0.0	0.0	0.0	1.16	127.8	0.0


Woods Hardwick		Page 3
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions		Network 2014.1.1

Network Design Table for Storm















PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
5.000	54.889	0.280	196.0	0.094	6.00	0.0	0.600	o	225	
5.001	23.748	0.054	439.8	0.080	0.00	0.0	0.600	o	450	
1.014	44.270	0.090	491.9	0.000	0.00	0.0	0.600	3 \=/	525	
1.015	6.454	0.015	430.3	0.000	0.00	0.0	0.600	o	525	
1.016	4.436	0.009	492.9	0.000	0.00	0.0	0.600	o	525	
6.000	25.590	0.455	56.2	0.108	6.00	0.0	0.600	o	225	
7.000	18.881	0.080	236.0	0.065	6.00	0.0	0.600	o	300	
6.001	15.459	0.070	220.8	0.040	0.00	0.0	0.600	o	300	
6.002	10.259	0.050	205.2	0.000	0.00	0.0	0.600	o	300	
6.003	18.087	0.095	190.4	0.065	0.00	0.0	0.600	o	300	
8.000	9.323	0.060	155.4	0.067	6.00	0.0	0.600	o	225	
9.000	16.200	0.130	124.6	0.017	6.00	0.0	0.600	o	225	
8.001	32.282	0.195	165.5	0.009	0.00	0.0	0.600	o	225	
8.002	26.594	0.115	231.3	0.107	0.00	0.0	0.600	o	300	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
5.000	0.00	6.98	123.060	0.094	0.0	0.0	0.0	0.93	37.0	0.0
5.001	0.00	7.39	122.780	0.174	0.0	0.0	0.0	0.96	153.2	0.0
1.014	0.00	12.31	122.726	1.228	0.0	0.0	0.0	0.84	122.9	0.0
1.015	0.00	12.41	122.635	1.228	0.0	0.0	0.0	1.07	232.4	0.0
1.016	0.00	12.49	122.620	1.228	0.0	0.0	0.0	1.00	216.9	0.0
6.000	0.00	6.24	123.100	0.108	0.0	0.0	0.0	1.75	69.5	0.0
7.000	0.00	6.31	122.650	0.065	0.0	0.0	0.0	1.02	72.0	0.0
6.001	0.00	6.55	122.570	0.213	0.0	0.0	0.0	1.05	74.5	0.0
6.002	0.00	6.71	122.500	0.213	0.0	0.0	0.0	1.09	77.3	0.0
6.003	0.00	6.97	122.450	0.278	0.0	0.0	0.0	1.14	80.3	0.0
8.000	0.00	6.15	122.800	0.067	0.0	0.0	0.0	1.05	41.6	0.0
9.000	0.00	6.23	122.870	0.017	0.0	0.0	0.0	1.17	46.5	0.0
8.001	0.00	6.76	122.740	0.093	0.0	0.0	0.0	1.01	40.3	0.0
8.002	0.00	7.19	122.470	0.200	0.0	0.0	0.0	1.03	72.8	0.0


Woods Hardwick		Page 4
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions		Network 2014.1.1

Network Design Table for Storm

















PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
6.004	59.029	0.150	393.5	0.067	0.00	0.0	0.600	o	525	
6.005	15.889	0.040	397.2	0.190	0.00	0.0	0.600	o	525	
10.000	21.879	0.095	230.3	0.140	6.00	0.0	0.600	o	300	
1.017	60.578	0.121	500.6	0.000	0.00	0.0	0.600	3 \=/	900	
11.000	34.108	0.200	170.5	0.102	6.00	0.0	0.600	o	225	
11.001	24.426	0.425	57.5	0.100	0.00	0.0	0.600	o	225	
12.000	21.313	0.206	103.5	0.094	6.00	0.0	0.600	o	225	
1.018	10.565	0.020	528.3	0.000	0.00	0.0	0.600	o	900	
1.019	15.518	0.048	323.3	0.000	0.00	0.0	0.600	o	750	
1.020	33.421	0.058	576.2	0.000	0.00	0.0	0.600	o	600	
13.000	18.480	1.059	17.5	0.090	6.00	0.0	0.600	o	150	
1.021	36.931	0.074	499.1	0.000	0.00	0.0	0.600	3 \=/	600	
14.000	15.326	0.062	247.2	0.051	6.00	0.0	0.600	o	300	
14.001	38.915	0.160	243.2	0.068	0.00	0.0	0.600	o	300	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
6.004	0.00	8.07	122.130	0.545	0.0	0.0	0.0	1.12	243.1	0.0
6.005	0.00	8.31	121.980	0.735	0.0	0.0	0.0	1.12	241.9	0.0
10.000	0.00	6.35	122.820	0.140	0.0	0.0	0.0	1.03	72.9	0.0
1.017	0.00	13.63	121.940	2.103	0.0	0.0	0.0	0.89	179.5	0.0
11.000	0.00	6.57	122.700	0.102	0.0	0.0	0.0	1.00	39.7	0.0
11.001	0.00	6.80	122.500	0.202	0.0	0.0	0.0	1.73	68.7	0.0
12.000	0.00	6.28	122.300	0.094	0.0	0.0	0.0	1.29	51.1	0.0
1.018	0.00	13.76	121.720	2.399	0.0	0.0	0.0	1.36	862.8	0.0
1.019	0.00	13.92	121.700	2.399	0.0	0.0	0.0	1.55	685.2	0.0
1.020	0.00	14.47	121.650	2.399	0.0	0.0	0.0	1.01	284.8	0.0
13.000	0.00	6.13	122.750	0.090	0.0	0.0	0.0	2.42	42.8	0.0
1.021	0.00	15.20	121.591	2.489	0.0	0.0	0.0	0.85	133.4	0.0
14.000	0.00	6.26	121.670	0.051	0.0	0.0	0.0	1.00	70.4	0.0
14.001	0.00	6.90	121.608	0.119	0.0	0.0	0.0	1.00	70.9	0.0


Woods Hardwick		Page 5
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions		Network 2014.1.1

Network Design Table for Storm

















PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
14.002	23.550	0.097	242.8	0.030	0.00	0.0	0.600	o	300	
14.003	26.177	0.100	261.8	0.001	0.00	0.0	0.600	o	300	
15.000	7.525	0.300	25.1	0.033	6.00	0.0	0.600	o	300	
15.001	33.256	0.270	123.2	0.048	0.00	0.0	0.600	o	300	
15.002	17.857	0.180	99.2	0.092	0.00	0.0	0.600	o	375	
16.000	25.888	0.415	62.4	0.045	6.00	0.0	0.600	o	225	
16.001	23.292	0.190	122.6	0.124	0.00	0.0	0.600	o	225	
15.003	62.260	0.580	107.3	0.135	0.00	0.0	0.600	o	525	
17.000	23.364	0.335	69.7	0.107	6.00	0.0	0.600	o	225	
17.001	51.510	0.320	161.0	0.132	0.00	0.0	0.600	o	375	
17.002	80.231	0.310	258.8	0.093	0.00	0.0	0.600	o	375	
17.003	49.516	0.160	309.5	0.050	0.00	0.0	0.600	o	525	
15.004	28.254	0.075	376.7	0.076	0.00	0.0	0.600	o	600	
15.005	45.556	0.253	180.1	0.078	0.00	0.0	0.600	o	750	
18.000	37.000	0.090	411.1	0.060	6.00	10.8	0.600	o	450	
18.001	11.062	0.027	409.7	0.010	0.00	0.0	0.600	o	450	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
14.002	0.00	7.29	121.448	0.149	0.0	0.0	0.0	1.00	71.0	0.0
14.003	0.00	7.74	121.351	0.150	0.0	0.0	0.0	0.97	68.4	0.0
15.000	0.00	6.04	124.300	0.033	0.0	0.0	0.0	3.15	222.8	0.0
15.001	0.00	6.43	124.000	0.081	0.0	0.0	0.0	1.42	100.1	0.0
15.002	0.00	6.59	123.655	0.173	0.0	0.0	0.0	1.82	200.9	0.0
16.000	0.00	6.26	124.230	0.045	0.0	0.0	0.0	1.66	66.0	0.0
16.001	0.00	6.59	123.815	0.169	0.0	0.0	0.0	1.18	46.9	0.0
15.003	0.00	7.08	123.325	0.477	0.0	0.0	0.0	2.16	467.9	0.0
17.000	0.00	6.25	124.170	0.107	0.0	0.0	0.0	1.57	62.3	0.0
17.001	0.00	6.85	123.685	0.239	0.0	0.0	0.0	1.43	157.4	0.0
17.002	0.00	8.04	123.365	0.332	0.0	0.0	0.0	1.12	123.9	0.0
17.003	0.00	8.69	122.905	0.382	0.0	0.0	0.0	1.27	274.5	0.0
15.004	0.00	9.07	122.670	0.935	0.0	0.0	0.0	1.25	353.0	0.0
15.005	0.00	9.44	122.445	1.013	0.0	0.0	0.0	2.08	920.0	0.0
18.000	0.00	6.62	122.309	0.060	10.8	0.0	0.0	1.00	158.5	10.8
18.001	0.00	6.80	122.219	0.070	10.8	0.0	0.0	1.00	158.7	10.8


Woods Hardwick		Page 6
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41 File SW West Proposed 13.04....	Designed by a.tew Checked by	
XP Solutions		Network 2014.1.1

Network Design Table for Storm




















PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
15.006	26.656	0.035	761.6	0.010	0.00	0.0	0.600	o	750	
15.007	39.783	0.052	765.1	0.134	0.00	0.0	0.600	o	750	
15.008	37.152	0.048	774.0	0.130	0.00	0.0	0.600	o	750	
15.009	77.855	0.100	778.6	0.246	0.00	0.0	0.600	o	750	
15.010	13.442	0.018	746.8	0.130	0.00	0.0	0.600	o	750	
15.011	38.118	0.049	777.9	0.009	0.00	0.0	0.600	o	750	
19.000	14.910	0.100	149.1	0.050	6.00	0.0	0.600	o	150	
19.001	11.780	0.040	294.5	0.055	0.00	0.0	0.600	o	375	
19.002	12.326	0.045	273.9	0.070	0.00	0.0	0.600	o	375	
15.012	63.874	0.086	742.7	0.115	0.00	0.0	0.600	o	750	
15.013	16.570	0.023	720.4	0.057	0.00	0.0	0.600	o	750	
14.004	18.318	0.027	678.4	0.000	0.00	0.0	0.600	3 \=/	750	
1.022	5.384	0.009	598.2	0.000	0.00	0.0	0.600	o	900	
1.023	2.428	0.005	485.6	0.000	0.00	0.0	0.600	o	900	
20.000	141.271	0.323	437.4	1.930	6.00	0.0	0.600	o	825	
20.001	22.063	0.063	350.2	0.000	0.00	0.0	0.600	oo	-3	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	Σ Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
15.006	0.00	9.88	122.192	1.093	10.8	0.0	0.0	1.01	444.5	10.8
15.007	0.00	10.54	122.157	1.227	10.8	0.0	0.0	1.00	443.5	10.8
15.008	0.00	11.16	122.105	1.357	10.8	0.0	0.0	1.00	440.9	10.8
15.009	0.00	12.46	122.057	1.603	10.8	0.0	0.0	1.00	439.6	10.8
15.010	0.00	12.68	121.957	1.733	10.8	0.0	0.0	1.02	448.9	10.8
15.011	0.00	13.32	121.939	1.742	10.8	0.0	0.0	1.00	439.8	10.8
19.000	0.00	6.30	121.920	0.050	0.0	0.0	0.0	0.82	14.5	0.0
19.001	0.00	6.49	121.820	0.105	0.0	0.0	0.0	1.05	116.0	0.0
19.002	0.00	6.68	121.780	0.175	0.0	0.0	0.0	1.09	120.4	0.0
15.012	0.00	14.37	121.360	2.032	10.8	0.0	0.0	1.02	450.2	10.8
15.013	0.00	14.63	121.274	2.089	10.8	0.0	0.0	1.03	457.2	10.8
14.004	0.00	15.04	121.251	2.239	10.8	0.0	0.0	0.74	133.9	10.8
1.022	0.00	15.27	121.224	4.728	10.8	0.0	0.0	1.27	810.3	10.8
1.023	0.00	15.30	121.215	4.728	10.8	0.0	0.0	1.42	900.2	10.8
20.000	0.00	7.67	123.463	1.930	0.0	0.0	0.0	1.41	755.4	0.0
20.001	0.00	7.92	123.140	1.930	0.0	0.0	0.0	1.43	1098.6	0.0

Woods Hardwick		Page 7
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions		Network 2014.1.1




Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
20.002	81.476	0.182	447.7	0.050	0.00	0.0	0.600	o	750	
20.003	4.000	0.010	400.0	0.000	0.00	0.0	0.600	o	750	
20.004	27.166	0.080	339.6	0.000	0.00	0.0	0.600	o	750	
21.000	11.633	1.490	7.8	0.255	6.00	0.0	0.600	o	150	
20.005	41.906	0.425	98.6	0.000	0.00	0.0	0.600	o	750	
20.006	10.069	0.025	402.8	0.000	0.00	0.0	0.600	o	750	
20.007	89.212	0.237	376.4	0.000	0.00	0.0	0.600	o	750	
20.008	45.691	0.108	423.1	0.000	0.00	0.0	0.600	o	750	
20.009	48.256	0.242	199.4	0.000	0.00	0.0	0.600	o	750	
20.010	74.990	0.218	344.0	0.000	0.00	0.0	0.600	o	750	
1.024	75.149	0.300	250.5	0.000	0.00	0.0	0.600	o	900	
1.025	14.377	0.020	718.9	0.000	0.00	0.0	0.600	o	900	
1.026	12.562	0.020	628.1	0.000	0.00	0.0	0.600	o	900	
1.027	43.989	0.080	549.9	0.000	0.00	0.0	0.600	o	900	
1.028	11.362	0.027	420.8	0.000	0.00	0.0	0.600	o	900	
1.029	49.420	0.133	371.6	1.000	0.00	0.0	0.600	o	900	
1.030	36.960	0.265	139.5	1.000	0.00	0.0	0.600	o	900	
1.031	119.800	0.640	187.2	0.500	0.00	0.0	0.600	o	900	
1.032	1.350	0.005	270.0	0.000	0.00	0.0	0.600	o	600	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	Σ I.Area (ha)	E Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
20.002	0.00	8.96	123.027	1.980	0.0	0.0	0.0	1.32	581.4	0.0
20.003	0.00	9.00	122.845	1.980	0.0	0.0	0.0	1.39	615.4	0.0
20.004	0.00	9.30	122.535	1.980	0.0	0.0	0.0	1.51	668.4	0.0
21.000	0.00	6.05	124.545	0.255	0.0	0.0	0.0	3.63	64.1	0.0
20.005	0.00	9.55	122.455	2.235	0.0	0.0	0.0	2.82	1245.2	0.0
20.006	0.00	9.67	122.030	2.235	0.0	0.0	0.0	1.39	613.3	0.0
20.007	0.00	10.71	122.005	2.235	0.0	0.0	0.0	1.44	634.6	0.0
20.008	0.00	11.27	121.768	2.235	0.0	0.0	0.0	1.35	598.3	0.0
20.009	0.00	11.68	121.660	2.235	0.0	0.0	0.0	1.98	873.9	0.0
20.010	0.00	12.51	121.418	2.235	0.0	0.0	0.0	1.50	664.1	0.0
1.024	0.00	15.93	121.050	6.963	10.8	0.0	0.0	1.98	1256.6	10.8
1.025	0.00	16.14	120.750	6.963	10.8	0.0	0.0	1.16	738.5	10.8
1.026	0.00	16.31	120.730	6.963	10.8	0.0	0.0	1.24	790.6	10.8
1.027	0.00	16.86	120.710	6.963	10.8	0.0	0.0	1.33	845.5	10.8
1.028	0.00	16.99	120.630	6.963	10.8	0.0	0.0	1.52	967.6	10.8
1.029	0.00	17.49	120.583	7.963	10.8	0.0	0.0	1.62	1030.3	10.8
1.030	0.00	17.73	120.450	8.963	10.8	0.0	0.0	2.65	1686.8	10.8
1.031	0.00	18.60	120.185	9.463	10.8	0.0	0.0	2.29	1454.9	10.8
1.032	0.00	18.61	119.545	9.463	10.8	0.0	0.0	1.48	417.7	10.8

Network Design Table for Storm

PN	Length (m)	Fall (m)	Slope (1:X)	I.Area (ha)	T.E. (mins)	Base Flow (l/s)	k (mm)	HYD SECT	DIA (mm)	Auto Design
1.033	184.800	2.050	90.1	0.000	0.00	0.0	0.600	\	-4	
1.034	149.300	1.770	84.4	0.000	0.00	0.0	0.600	\	-4	
1.035	2.700	0.030	90.0	0.000	0.00	0.0	0.600	oo	45	

Network Results Table

PN	Rain (mm/hr)	T.C. (mins)	US/IL (m)	E I.Area (ha)	E Base Flow (l/s)	Foul (l/s)	Add Flow (l/s)	Vel (m/s)	Cap (l/s)	Flow (l/s)
1.033	0.00	19.15	119.140	9.463	10.8	0.0	0.0	5.80	15082.6	10.8
1.034	0.00	19.56	117.090	9.463	10.8	0.0	0.0	6.00	15593.3	10.8
1.035	0.00	19.58	115.320	9.463	10.8	0.0	0.0	2.57	1450.0	10.8

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
------------------------	-----------------	-----------------	-----------------	------------------------	-------------	-----------

1.035	Watercourse	116.500	115.290	0.000	0	0
-------	-------------	---------	---------	-------	---	---


Simulation Criteria for Storm

Volumetric Runoff Coeff	0.840	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m ³ /ha Storage	1.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1

Number of Input Hydrographs	0	Number of Storage Structures	8
Number of Online Controls	4	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0


Synthetic Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
Site Location	GB 450500 225250 SP 50500 25250
C (1km)	-0.023
D1 (1km)	0.328
D2 (1km)	0.309
D3 (1km)	0.264
E (1km)	0.292
F (1km)	2.461
Summer Storms	No
Winter Storms	Yes
Cv (Summer)	0.750

Woods Hardwick		Page 9
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41 File SW West Proposed 13.04....	Designed by a.tew Checked by	
XP Solutions	Network 2014.1.1	

Synthetic Rainfall Details

Cv (Winter) 0.840
Storm Duration (mins) 15

Woods Hardwick		Page 10
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions	Network 2014.1.1	

Online Controls for Storm

Hydro-Brake® Manhole: 10 (HW), DS/PN: 1.012, Volume (m³): 439.1

Design Head (m) 1.800 Hydro-Brake® Type Md6 SW Only Invert Level (m) 122.890
 Design Flow (l/s) 7.1 Diameter (mm) 96

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	2.9	1.200	5.8	3.000	9.1	7.000	13.9
0.200	4.3	1.400	6.2	3.500	9.8	7.500	14.4
0.300	4.1	1.600	6.7	4.000	10.5	8.000	14.9
0.400	4.0	1.800	7.1	4.500	11.2	8.500	15.3
0.500	4.0	2.000	7.4	5.000	11.8	9.000	15.8
0.600	4.2	2.200	7.8	5.500	12.3	9.500	16.2
0.800	4.7	2.400	8.1	6.000	12.9		
1.000	5.3	2.600	8.5	6.500	13.4		

Hydro-Brake® Manhole: 14 (HB), DS/PN: 1.016, Volume (m³): 5.4

Design Head (m) 0.600 Hydro-Brake® Type Md6 SW Only Invert Level (m) 122.620
 Design Flow (l/s) 14.2 Diameter (mm) 159

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	5.3	1.200	16.0	3.000	25.0	7.000	38.2
0.200	12.3	1.400	17.1	3.500	27.0	7.500	39.5
0.300	15.0	1.600	18.3	4.000	28.8	8.000	40.8
0.400	15.1	1.800	19.4	4.500	30.6	8.500	42.1
0.500	14.6	2.000	20.4	5.000	32.3	9.000	43.3
0.600	14.1	2.200	21.4	5.500	33.8	9.500	44.5
0.800	14.1	2.400	22.3	6.000	35.3		
1.000	14.9	2.600	23.3	6.500	36.8		


Pre-initialised control selected, excessive flows may result.

Hydro-Brake® Manhole: 18 (HB), DS/PN: 1.020, Volume (m³): 11.0

Design Head (m) 0.750 Hydro-Brake® Type Md6 SW Only Invert Level (m) 121.650
 Design Flow (l/s) 61.5 Diameter (mm) 279

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	9.1	1.200	57.0	3.000	77.0	7.000	117.5
0.200	25.9	1.400	57.5	3.500	83.1	7.500	121.6
0.300	42.9	1.600	59.1	4.000	88.8	8.000	125.6
0.400	55.5	1.800	61.2	4.500	94.2	8.500	129.5
0.500	60.8	2.000	63.8	5.000	99.3	9.000	133.2
0.600	62.0	2.200	66.4	5.500	104.2	9.500	136.9
0.800	60.6	2.400	69.1	6.000	108.8		
1.000	58.1	2.600	71.8	6.500	113.2		

Pre-initialised control selected, excessive flows may result.


Woods Hardwick		Page 11
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41 File SW West Proposed 13.04....	Designed by a.tew Checked by	
XP Solutions		Network 2014.1.1

Hydro-Brake® Manhole: 21 (HB), DS/PN: 1.023, Volume (m³): 7.8

Design Head (m) 1.100 Hydro-Brake® Type Md6 SW Only Invert Level (m) 121.215
Design Flow (l/s) 194.0 Diameter (mm) 441

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	13.6	1.200	191.9	3.000	196.2	7.000	293.6
0.200	41.5	1.400	186.6	3.500	209.2	7.500	303.9
0.300	75.6	1.600	182.0	4.000	222.6	8.000	313.8
0.400	110.6	1.800	179.4	4.500	235.7	8.500	323.5
0.500	142.5	2.000	179.0	5.000	248.2	9.000	332.9
0.600	168.0	2.200	180.4	5.500	260.3	9.500	342.0
0.800	191.4	2.400	183.2	6.000	271.8		
1.000	194.7	2.600	186.9	6.500	282.9		

Pre-initialised control selected, excessive flows may result.

Woods Hardwick		Page 12
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41 File SW West Proposed 13.04....	Designed by a.tew Checked by	
XP Solutions		Network 2014.1.1

Storage Structures for Storm

Porous Car Park Manhole: 8 (B3), DS/PN: 1.005

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	8.0
Membrane Percolation (mm/hr)	1000	Length (m)	14.0
Max Percolation (l/s)	31.1	Slope (1:X)	1000.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	124.800	Cap Volume Depth (m)	0.000

Porous Car Park Manhole: 9 (B3), DS/PN: 1.006

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	31.9
Membrane Percolation (mm/hr)	1000	Length (m)	20.0
Max Percolation (l/s)	177.2	Slope (1:X)	0.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	125.080	Cap Volume Depth (m)	0.000

Complex Manhole: 9 (HW), DS/PN: 1.011

Tank or Pond

Invert Level (m) 122.952

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	65.0	2.400	430.0


Tank or Pond Manhole: 12 (HW), DS/PN: 1.014

Invert Level (m) 122.726

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	173.0	1.800	746.0

Porous Car Park Manhole: 36 (B2a), DS/PN: 6.000

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	14.1
Membrane Percolation (mm/hr)	1000	Length (m)	20.0
Max Percolation (l/s)	78.3	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	124.280	Cap Volume Depth (m)	0.000

Woods Hardwick		Page 13
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41 File SW West Proposed 13.04....	Designed by a.tew Checked by	
XP Solutions		Network 2014.1.1

Porous Car Park Manhole: 43 (B2a), DS/PN: 8.001

Infiltration Coefficient Base (m/hr)	0.00000	Width (m)	6.6
Membrane Percolation (mm/hr)	1000	Length (m)	25.0
Max Percolation (l/s)	45.8	Slope (1:X)	100.0
Safety Factor	2.0	Depression Storage (mm)	5
Porosity	0.30	Evaporation (mm/day)	3
Invert Level (m)	123.840	Cap Volume Depth (m)	0.000

Tank or Pond Manhole: 16 (HW), DS/PN: 1.018


Invert Level (m) 121.720

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	640.0	2.150	1751.0

Tank or Pond Manhole: 20 (HW), DS/PN: 1.022

Invert Level (m) 121.224

Depth (m)	Area (m ²)	Depth (m)	Area (m ²)
0.000	297.0	2.000	1420.0

Woods Hardwick		Page 14
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41	Designed by a.tew	
File SW West Proposed 13.04....	Checked by	
XP Solutions		Network 2014.1.1

Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor 1.000 Additional Flow - % of Total Flow 0.000
Hot Start (mins) 0 MADD Factor * 10m³/ha Storage 1.000
Hot Start Level (mm) 0 Inlet Coefficient 0.800
Manhole Headloss Coeff (Global) 0.500 Flow per Person per Day (l/per/day) 0.000
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0 Number of Storage Structures 8
Number of Online Controls 4 Number of Time/Area Diagrams 0
Number of Offline Controls 0 Number of Real Time Controls 0


Synthetic Rainfall Details

Rainfall Model FEH
Site Location GB 450500 225250 SP 50500 25250
C (1km) -0.023
D1 (1km) 0.328
D2 (1km) 0.309
D3 (1km) 0.264
E (1km) 0.292
F (1km) 2.461
Cv (Summer) 0.750
Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0
Analysis Timestep 2.5 Second Increment (Extended)
DTS Status ON
DVD Status ON
Inertia Status OFF

Profile(s) Summer and Winter
Duration(s) (mins) 15, 30, 60, 120, 240, 360, 480, 960, 1440
Return Period(s) (years) 100
Climate Change (%) 30

PN	Storm	Return Period	Climate Change	First X Surcharge	First Y Flood	First Z Overflow Act.	O/F	Lvl Exc.
1.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
1.001	15 Winter	100	+30%	100/15 Summer				
1.002	15 Winter	100	+30%	100/15 Summer				
1.003	15 Winter	100	+30%	100/15 Summer	100/15 Winter			1
2.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
1.004	15 Winter	100	+30%	100/15 Summer				
1.005	15 Winter	100	+30%	100/15 Summer				
1.006	15 Winter	100	+30%	100/15 Summer				
1.007	15 Winter	100	+30%	100/15 Summer				
1.008	480 Winter	100	+30%	100/15 Summer				
1.009	480 Winter	100	+30%	100/15 Summer				
3.000	480 Winter	100	+30%	100/15 Summer				
3.001	480 Winter	100	+30%	100/15 Summer				
3.002	480 Winter	100	+30%	100/15 Summer				
1.010	480 Winter	100	+30%	100/15 Summer				

Woods Hardwick		Page 15
15-17 Goldington Road Bedford Bedfordshire MK40 3NH		
Date 24/10/2017 11:41 File SW West Proposed 13.04....	Designed by a.tew Checked by	
XP Solutions		Network 2014.1.1

Summary of Critical Results by Maximum Level (Rank 1) for Storm


PN	Storm	Return Period	Climate Change	First X SurchARGE	First Y Flood	First Z Overflow	O/F Act.	Lvl Exc.
1.011	480 Winter	100	+30%					
1.012	480 Winter	100	+30%	100/15 Summer				
1.013	120 Winter	100	+30%					
4.000	15 Winter	100	+30%					
4.001	15 Winter	100	+30%	100/15 Winter				
4.002	15 Winter	100	+30%	100/15 Summer				
5.000	15 Winter	100	+30%	100/15 Summer	100/15 Winter			1
5.001	120 Winter	100	+30%					
1.014	120 Winter	100	+30%					
1.015	120 Winter	100	+30%	100/60 Winter				
1.016	120 Winter	100	+30%	100/60 Winter				
6.000	15 Winter	100	+30%	100/15 Summer				
7.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
6.001	15 Winter	100	+30%	100/15 Summer				
6.002	15 Winter	100	+30%	100/15 Summer				
6.003	15 Winter	100	+30%	100/15 Summer				
8.000	15 Winter	100	+30%	100/15 Summer				
9.000	15 Winter	100	+30%	100/15 Summer				
8.001	15 Winter	100	+30%	100/15 Summer				
8.002	15 Winter	100	+30%	100/15 Summer				
6.004	15 Winter	100	+30%	100/15 Summer				
6.005	15 Winter	100	+30%	100/15 Summer				
10.000	15 Winter	100	+30%	100/15 Summer				
1.017	120 Winter	100	+30%					
11.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			3
11.001	15 Summer	100	+30%	100/15 Summer				
12.000	15 Winter	100	+30%	100/15 Summer				
1.018	120 Winter	100	+30%					
1.019	120 Winter	100	+30%	100/120 Winter				
1.020	120 Winter	100	+30%	100/15 Winter				
13.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
1.021	60 Winter	100	+30%					
14.000	60 Winter	100	+30%	100/15 Summer				
14.001	60 Winter	100	+30%	100/15 Summer				
14.002	60 Winter	100	+30%	100/15 Summer				
14.003	60 Winter	100	+30%	100/15 Summer				
15.000	15 Winter	100	+30%					
15.001	15 Winter	100	+30%	100/15 Winter				
15.002	15 Winter	100	+30%	100/15 Winter				
16.000	15 Winter	100	+30%	100/15 Summer				
16.001	15 Winter	100	+30%	100/15 Summer				
15.003	15 Winter	100	+30%	100/15 Summer				
17.000	15 Winter	100	+30%	100/15 Summer				
17.001	15 Winter	100	+30%	100/15 Summer				
17.002	15 Winter	100	+30%	100/15 Summer				
17.003	15 Winter	100	+30%	100/15 Summer				
15.004	15 Winter	100	+30%	100/15 Summer				
15.005	15 Winter	100	+30%	100/15 Summer				
18.000	15 Winter	100	+30%	100/15 Summer	100/15 Winter			1
18.001	15 Winter	100	+30%	100/15 Summer				
15.006	15 Winter	100	+30%	100/15 Summer				

Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	Storm	Return Period	Climate Change	First X SurchARGE	First Y Flood	First Z Overflow	O/F Act.	Lvl Exc.
15.007	15 Winter	100	+30%	100/15 Summer				
15.008	15 Winter	100	+30%	100/15 Summer				
15.009	15 Winter	100	+30%	100/15 Summer				
15.010	15 Winter	100	+30%	100/15 Summer				
15.011	15 Winter	100	+30%	100/15 Summer				
19.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
19.001	60 Winter	100	+30%	100/15 Summer				
19.002	60 Winter	100	+30%	100/15 Summer				
15.012	60 Winter	100	+30%	100/15 Summer				
15.013	60 Winter	100	+30%	100/15 Summer				
14.004	60 Winter	100	+30%					
1.022	60 Winter	100	+30%	100/15 Summer				
1.023	60 Winter	100	+30%	100/15 Summer				
20.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
20.001	15 Winter	100	+30%	100/15 Summer				
20.002	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
20.003	15 Summer	100	+30%	100/15 Summer				
20.004	15 Winter	100	+30%	100/15 Summer				
21.000	15 Winter	100	+30%	100/15 Summer	100/15 Summer			6
20.005	15 Winter	100	+30%	100/15 Summer				
20.006	15 Winter	100	+30%	100/15 Summer				
20.007	15 Winter	100	+30%	100/15 Summer				
20.008	15 Winter	100	+30%	100/15 Summer				
20.009	15 Winter	100	+30%	100/15 Summer				
20.010	15 Winter	100	+30%	100/15 Summer				
1.024	30 Winter	100	+30%	100/30 Winter				
1.025	30 Winter	100	+30%	100/15 Summer				
1.026	30 Winter	100	+30%	100/15 Summer				
1.027	15 Winter	100	+30%	100/15 Summer				
1.028	15 Winter	100	+30%	100/15 Summer				
1.029	15 Winter	100	+30%	100/15 Summer				
1.030	15 Winter	100	+30%	100/15 Summer				
1.031	15 Winter	100	+30%	100/15 Summer				
1.032	15 Winter	100	+30%	100/15 Summer	100/15 Summer			2
1.033	15 Winter	100	+30%					
1.034	15 Winter	100	+30%					
1.035	15 Winter	100	+30%	100/15 Summer				

PN	US/MH Name	Water Level (m)	Surch'd Depth (m)	Flooded Volume (m³)	Flow / Cap.	O'flow (l/s)	Pipe Flow (l/s)	Status
1.000	2 (B3)	125.936	1.211	5.869	1.35	0.0	53.3	FLOOD
1.001	3 (B3)	126.007	1.442	0.000	0.86	0.0	58.4	FLOOD RISK
1.002	4 (B3)	125.958	1.543	0.000	1.30	0.0	103.7	FLOOD RISK
1.003	5 (B3)	125.690	1.465	0.056	2.08	0.0	155.7	FLOOD
2.000	6 (B3)	125.278	1.028	7.602	0.45	0.0	52.4	FLOOD
1.004	7 (B3)	125.324	1.199	0.000	1.18	0.0	198.4	FLOOD RISK
1.005	8 (B3)	125.226	1.196	0.000	1.39	0.0	214.7	FLOOD RISK
1.006	9 (B3)	125.081	1.131	0.000	1.69	0.0	282.4	SURCHARGED
1.007	10 (B3)	124.647	1.097	0.000	2.08	0.0	273.8	SURCHARGED

15-17 Goldington Road
 Bedford
 Bedfordshire MK40 3NH



Date 24/10/2017 11:41
 File SW West Proposed 13.04....

Designed by a.tew
 Checked by

XP Solutions

Network 2014.1.1

Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Water Level (m)	Surch'd Depth (m)	Flooded Volume (m ³)	Flow / Cap.	O'flow (l/s)	Pipe Flow (l/s)	Status
1.008	7 (B2b)	124.621	0.950	0.000	0.22	0.0	44.7	SURCHARGED
1.009	8a (B2b)	124.618	1.083	0.000	0.36	0.0	44.4	SURCHARGED
3.000	29 (B2a)	124.621	0.671	0.000	0.08	0.0	5.9	SURCHARGED
3.001	30 (B2a)	124.619	0.899	0.000	0.10	0.0	5.7	SURCHARGED
3.002	30a (B2a)	124.619	0.929	0.000	0.15	0.0	10.0	SURCHARGED
1.010	8	124.617	1.102	0.000	0.36	0.0	54.1	SURCHARGED
1.011	9 (HW)	124.616	-0.766	0.000	0.00	0.0	27.3	OK
1.012	10 (HW)	124.615	1.200	0.000	0.04	0.0	6.7	FLOOD RISK
1.013	11 (HB)	123.185	-0.220	0.000	0.05	0.0	6.2	OK
4.000	31 (B2a)	123.381	-0.094	0.000	0.60	0.0	65.1	OK
4.001	32 (B2a)	123.315	0.010	0.000	0.96	0.0	98.0	SURCHARGED
4.002	33 (B2a)	123.219	0.014	0.000	1.09	0.0	109.1	SURCHARGED
5.000	34 (B2b)	124.000	0.715	0.111	1.74	0.0	62.0	FLOOD
5.001	35 (B2b)	123.191	-0.039	0.000	0.26	0.0	32.7	OK
1.014	12 (HW)	123.184	-1.335	0.000	0.00	0.0	29.1	OK
1.015	13 (HW)	123.183	0.023	0.000	0.11	0.0	15.9	SURCHARGED
1.016	14 (HB)	123.186	0.041	0.000	0.09	0.0	15.1	SURCHARGED
6.000	36 (B2a)	124.325	1.000	0.000	1.11	0.0	71.4	FLOOD RISK
7.000	42 (B2a)	123.795	0.845	5.251	0.86	0.0	53.8	FLOOD
6.001	37 (B2a)	123.823	0.953	0.000	1.82	0.0	114.1	SURCHARGED
6.002	38 (B2a)	123.649	0.849	0.000	1.92	0.0	116.8	SURCHARGED
6.003	39 (B2a)	123.483	0.733	0.000	2.12	0.0	146.1	SURCHARGED
8.000	45 (B2a)	123.907	0.882	0.000	1.28	0.0	43.8	FLOOD RISK
9.000	46 (B2a)	123.841	0.746	0.000	0.31	0.0	12.6	FLOOD RISK
8.001	43 (B2a)	123.824	0.859	0.000	1.61	0.0	61.0	SURCHARGED
8.002	44 (B2a)	123.447	0.677	0.000	1.79	0.0	117.2	SURCHARGED
6.004	40 (B2a)	123.050	0.395	0.000	1.36	0.0	299.5	SURCHARGED
6.005	41 (B2a)	122.756	0.251	0.000	2.60	0.0	419.1	SURCHARGED
10.000	Private (B2b)	123.239	0.119	0.000	1.55	0.0	99.7	SURCHARGED
1.017	15 (HW)	122.468	-1.832	0.000	0.01	0.0	185.6	OK
11.000	47 (B2b)	123.737	0.812	6.572	1.84	0.0	68.9	FLOOD
11.001	48 (B2b)	123.640	0.915	0.000	1.74	0.0	109.8	FLOOD RISK
12.000	49 (B2a)	122.734	0.209	0.000	1.43	0.0	66.6	SURCHARGED
1.018	16 (HW)	122.464	-0.156	0.000	0.10	0.0	34.5	OK
1.019	17 (HW)	122.466	0.016	0.000	0.08	0.0	34.6	SURCHARGED
1.020	18 (HB)	122.465	0.215	0.000	0.14	0.0	34.2	SURCHARGED
13.000	Private (B2b)	123.352	0.452	2.321	1.20	0.0	48.0	FLOOD
1.021	19 (HW)	122.435	-0.829	0.000	0.00	0.0	58.7	OK
14.000	59 (B2b)	122.454	0.484	0.000	0.27	0.0	15.7	SURCHARGED
14.001	60 (B2b)	122.452	0.544	0.000	0.55	0.0	36.4	SURCHARGED
14.002	61 (B2b)	122.446	0.698	0.000	0.71	0.0	44.8	SURCHARGED
14.003	62 (B2b)	122.441	0.790	0.000	0.72	0.0	44.1	SURCHARGED
15.000	Existing	124.403	-0.197	0.000	0.17	0.0	23.5	OK
15.001	11 (B3)	124.395	0.095	0.000	0.67	0.0	61.5	SURCHARGED
15.002	12 (B3)	124.301	0.271	0.000	0.82	0.0	135.6	SURCHARGED
16.000	13 (B3)	125.413	0.958	0.000	0.58	0.0	35.4	FLOOD RISK
16.001	14 (B3)	125.326	1.286	0.000	2.70	0.0	116.2	FLOOD RISK
15.003	15 (B3)	124.163	0.313	0.000	0.77	0.0	328.2	SURCHARGED
17.000	16 (B3)	125.553	1.158	0.000	1.21	0.0	69.1	FLOOD RISK
17.001	17 (B3)	125.098	1.038	0.000	1.00	0.0	146.1	FLOOD RISK

Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Water Level (m)	Surch'd Depth (m)	Flooded Volume (m ³)	Flow / Cap.	O'flow (l/s)	Pipe Flow (l/s)	Status
17.002	18 (B3)	124.800	1.060	0.000	1.62	0.0	191.2	FLOOD RISK
17.003	19 (B3)	124.083	0.653	0.000	0.84	0.0	204.8	SURCHARGED
15.004	20 (B3)	123.975	0.705	0.000	1.73	0.0	493.3	SURCHARGED
15.005	68 (B2b)	123.788	0.593	0.000	0.68	0.0	518.3	SURCHARGED
18.000	69 (B2b)	123.557	0.798	7.152	0.38	0.0	52.8	FLOOD
18.001	70 (B2b)	123.608	0.939	0.000	0.57	0.0	55.6	FLOOD RISK
15.006	71 (B2b)	123.623	0.681	0.000	1.93	0.0	543.9	SURCHARGED
15.007	72 (B2b)	123.550	0.643	0.000	1.60	0.0	578.8	SURCHARGED
15.008	73 (B2b)	123.422	0.567	0.000	1.74	0.0	606.9	SURCHARGED
15.009	74 (B2b)	123.265	0.458	0.000	1.64	0.0	642.5	SURCHARGED
15.010	75 (B2b)	122.974	0.267	0.000	3.34	0.0	668.9	SURCHARGED
15.011	76 (B2b)	122.788	0.099	0.000	1.87	0.0	659.9	SURCHARGED
19.000	77 (B2b)	122.721	0.651	1.154	2.09	0.0	28.0	FLOOD
19.001	78 (B2b)	122.488	0.293	0.000	0.38	0.0	33.4	SURCHARGED
19.002	79 (B2b)	122.486	0.331	0.000	0.60	0.0	55.9	SURCHARGED
15.012	80 (B2b)	122.482	0.372	0.000	1.40	0.0	549.3	SURCHARGED
15.013	81 (B2b)	122.454	0.430	0.000	2.65	0.0	553.6	SURCHARGED
14.004	HW 82 (B2b)	122.437	-0.773	0.000	0.06	0.0	584.1	OK
1.022	20 (HW)	122.435	0.311	0.000	0.36	0.0	181.1	SURCHARGED
1.023	21 (HB)	122.588	0.473	0.000	0.33	0.0	178.2	SURCHARGED
20.000	EX MH	125.374	1.086	21.497	1.66	0.0	1165.8	FLOOD
20.001	EX MH	124.859	1.019	0.000	1.34	0.0	1084.8	SURCHARGED
20.002	SD1	124.733	0.956	42.880	1.81	0.0	943.7	FLOOD
20.003	SD2	124.412	0.817	0.000	2.58	0.0	913.0	SURCHARGED
20.004	PI	124.173	0.888	0.000	1.77	0.0	896.6	SURCHARGED
21.000	0622	125.385	0.690	34.935	1.21	0.0	70.0	FLOOD
20.005	SD3	123.956	0.751	0.000	0.92	0.0	939.0	SURCHARGED
20.006	SD4	123.693	0.913	0.000	2.97	0.0	908.0	SURCHARGED
20.007	SD5	123.424	0.669	0.000	1.48	0.0	848.6	SURCHARGED
20.008	SD6	122.941	0.423	0.000	1.67	0.0	831.4	SURCHARGED
20.009	SD7	122.647	0.237	0.000	1.13	0.0	826.7	SURCHARGED
20.010	SD8	122.344	0.176	0.000	1.38	0.0	811.5	SURCHARGED
1.024	SD9	121.999	0.049	0.000	0.71	0.0	772.1	SURCHARGED
1.025	SD10	121.866	0.216	0.000	2.65	0.0	760.7	SURCHARGED
1.026	SD11	121.810	0.180	0.000	2.41	0.0	759.9	SURCHARGED
1.027	SD12	121.783	0.173	0.000	1.18	0.0	797.7	SURCHARGED
1.028	SD13	121.878	0.348	0.000	1.76	0.0	798.9	SURCHARGED
1.029	0307	121.942	0.459	0.000	0.95	0.0	795.0	SURCHARGED
1.030	0306	121.920	0.570	0.000	0.75	0.0	872.7	FLOOD RISK
1.031	0305	121.792	0.707	0.000	0.87	0.0	1151.3	FLOOD RISK
1.032	0369	121.245	1.100	10.883	4.50	0.0	1067.6	FLOOD
1.033	Channel	119.307	-0.833	0.000	0.08	0.0	1066.6	OK
1.034	Channel	117.255	-0.835	0.000	0.09	0.0	1065.7	OK
1.035	Double pipe	116.131	0.211	0.000	1.86	0.0	1042.0	SURCHARGED