

NOTES:

The foul & surface water design has been based on the approved principles outlined within the Flood Risk Assessment & Drainage Strategy undertaken by Forge Engineering Design Solutions.

Foul Water:

The foul water flows from each property will drain via gravity through the private house drainage before out-falling to a new sewer located typically within the development road network. All foul flow from the development gravitates in a southerly direction to a new foul outfall sewer constructed as part of the adjacent Cala Homes Development.

The development foul drainage network will be offered to Thames Water for adoption under a Section 104 agreement of the Water Industry Act 1991.

Surface Water:

The surface water drainage strategy sets of general principles for the designs. The sub strata is unsuitable for infiltration type SUDs and will therefore require a more traditional approach.

Due to the steepness of the development roads and drives permeable type paving is unsuitable. The surface water flows from each property will drain via gravity through the private house drainage before out-falling to a new storm drain located typically within the development road network. The development storm drainage discharges to an attenuation tank located towards the southern end of the site within the open space.

The controlled surface water discharge from the development will outfall to a new surface water outfall sewer constructed as part of the adjacent Cala Homes Development.

The following SUDs techniques are proposed for the development site and form part of the drainage treatment train.

- Piped storm drainage with associated deep trapped gullies and catchpits
- Cellular attenuation (1 in 100 + 40% climate change)
- Flow control
- Downstream defender


The final surface water runoff from the development will be strictly controlled via the above Sustainable Drainage Systems. The runoff rate is at the equivalent agreed Greenfield runoff rate and be designed to manage the 1 in 100 year return storm plus an extra allowance of 40% for the potential predicted increase in peak rainfall up to 2115.

KEY:

Proposed Adoptable Sewers:

Foul sewer 

Storm sewer 

Road Gully (no distinction between private or adopted at this time) 

Storm Attenuation (see plan for details) 

Proposed Private Drainage:

Foul drain 

Storm drain 

PRELIMINARY - FOR PLANNING

REV. No.	A	23.01.18	Revised in accordance with current planning layout (extents and layout).	AJW
Client	CREST NICHOLSON			INITIALS
Project	Bodicote, Banbury			
Title	Proposed Drainage Strategy Plan			
Scale	1:500 @A1	Date	Nov 2017	Drawing No.
Checked	KTG	Drawn	AJW	5692:P70
				Rev
				A

MJA CONSULTING
 CIVIL AND STRUCTURAL ENGINEERS
 Monarch House, Barton Lane,
 Abingdon, Oxon, OX14 3NB
 Tel: 01235 555173
 Fax: 01235 523226

