



**FOUL WATER SEWER LEGEND**

- 23 Proposed Phase number
- Proposed Foul Water Sewer
- Existing Foul Water Sewer (Subject to condition and capacity)
- Existing Foul Water Sewer to be diverted
- Proposed Rising Main
- Existing Rising Main
- Proposed Pumping Station
- Existing Pumping Station
- CL118.71 IL117.835 Proposed Cover level and Invert level obtained from Woods Hardwick drawing
- CL117.90 Cover level based on survey information
- Proposed Attenuation Basin

**NOTES**

- 1- Confirmation of capacity at existing foul treatment plant required for parcels 11 to 23.
- 2- Condition and route of existing sewers to be confirmed.
- 3- Residential flows based on 4000l/dwelling as specified in SFA 7th Edition.
- 4- Medical centre, retail space and changing facilities flows based on Plumbing Engineering Services Design Guide.

PO2	RFS	16-04-18	SM	16-04-18	SM	16-04-18
Updated Masterplan to layout Rev Y						
PO1	RFS	02.10.17	SM	02.10.17	SM	02.10.17
First issue						
REV	DRAWN BY	DATE	CHECKED BY	DATE	APPROVED BY	DATE

**Hydrock**  
 Over Court Barns  
 Over Lane  
 Almondsbury, Bristol BS32 4DF  
 TEL: 01454 619 533  
 FAX: 01454 614 125  
 E-Mail: bristol@hydrock.com  
 or visit www.hydrock.com

CLIENT  
**DORCHESTER LIVING**

PROJECT  
**HEYFORD PARK**

TITLE  
**FOUL WATER DRAINAGE STRATEGY PLAN**

HYDROCK PROJECT NO.  
**C-04583-C**

SCALE @ A1  
**1:5000**

PURPOSE OF ISSUE  
**SUITABLE FOR INFORMATION**

DRAWING NO. (PROJECT CODE-ORIGINATOR-ZONE-LEVEL-TYPE-ROLE-NUMBER)  
**HPH-HYD-XX-XX-DR-C-2202**

STATUS  
**S2**

REVISION  
**P2**