



**Street Lighting Key:**  
 Proposed 5m galvanised steel column with post top mounted at 5° Philips WRTL 18LED lantern.  
 Column Ref: Style 2 - See OCC Standard Detail HSD/12/010  
 Lantern Order Ref: 10-18 DS-CW 1 900-4650 CW LED  
 Switch Control: SELC 8482701 35 Lux On, 18 Lux off  
 LED Driver: Philips Xitanium  
 Service Connection: Private metered supply  
 Project quantity (10no.)

21A Unit numbers for general reference purposes only.

- Notes:**
- Do not scale this drawing.  
 Contractor to check all dimensions and report all errors and omissions to the engineer.
  - Private units are to be left unpainted, or painted a different colour to LA columns. (OCC paint colour is Reed Green)

THIS DESIGN HAS BEEN PREPARED IN ACCORDANCE WITH THE HEMSA GUIDANCE NOTE - CDM2007 REGULATIONS, ISSUE 1, DATED 12/05/08 PROCEDURE 2. THE INFORMATION ON THIS DRAWING DOES NOT ACCOUNT FOR INSTALLATION CONSIDERATIONS, SITE CONDITIONS, OR PROVIDE ANY FORM OF RISK ASSESSMENT. DESIGN SERVICE IS ADVISORY ONLY AND IT IS THE RESPONSIBILITY OF THE RECIPIENT OF THIS INFORMATION TO VERIFY THAT THE DESIGN IS SUITABLE FOR THE INTENDED APPLICATION. THE WHOLE AREA BEING CONSIDERED IS IN THE SAME PLANE, I.E. THERE ARE NO CHANGES IN GRADIENT OR ELERVATION.

Rev	By	Chkd	Appvd	Date	Description

Developer  
**BOVIS HOMES**

---

Development  
**LONGFORD PARK  
 (PRIVATE AREAS)**

---

Drawing  
**STREET LIGHTING LAYOUT  
 (SHEET 2 OF 2)**

---

Designer: PS Date Drawn: 05/05/17

---

Drawing No. **072/002** Revision  
 -

---

Drawing Scale: 1:1000 @A3